

VALLECITOS WATER DISTRICT

WOODWARD 46 WATER AND SEWER STUDY

WORK ORDER # 269767

FINAL TECHNICAL MEMORANDUM

April 6, 2023

Prepared By: Elizabeth Lopez, Development Services Senior Engineer, and Eileen Koonce

INTRODUCTION

The proposed Woodward 46 project (Project) is a 46-unit multi-family residential development on 8.6-acres, located on Woodward Street north of Mission Road in the City of San Marcos (APN 220-210-49).

The Project is located within Vallecitos Water District's (VWD) boundaries for water and wastewater service. The property does not need to annex, both water and wastewater services can be provided by VWD.

All new projects undergo evaluation by VWD to determine if the current water and sewer infrastructure is sufficient to accommodate the proposed water demands and sewage generation.

This study projects water demand and sewage generation increases due to the project densification. It analyzes the following aspects of VWD's infrastructure and makes recommendations for capital improvements for impacts that are created due to the land use change:

- Water distribution system, including the need to upsize pipelines, install new pipelines, or install flow control facilities.
- Water storage, including the need for additional storage and the adequacy of existing storage tanks and reservoirs to serve the proposed development.
- Water pump stations, including the need to install new pump stations or upsize existing pump stations to serve the proposed development.
- Wastewater collection system, including the need to upsize pipelines and manholes, or the need to install new pipelines and manholes.
- Wastewater lift stations, including the need to install new lift stations or upsize existing lift stations to serve the proposed development.
- Wastewater land outfall, including the need to construct a parallel land outfall to serve this and other proposed developments.

- Wastewater treatment facilities, including the need for obtaining additional capacity at the Encina Water Pollution Control Facility (EWPCF) or for expanding the Meadowlark Water Reclamation Facility (MRF).
- Existing VWD water and/or sewer facilities not being utilized for proposed development will need to be abandoned per VWD Standards and Specifications. Asbestos cement pipe shall be properly removed and legally disposed of by the Developer.

WATER SYSTEM ANALYSIS

The proposed 8.6-acre Project lies completely within VWD's 920 Pressure Zone. Figures 1 and 2 show the development's location in relation to pressure zone boundaries, identify pipelines within the vicinity of the development, and identify storage reservoirs that supply the development area.


Water Demand Projections

The Project property is within the City of San Marcos' Richmar Specific Plan Area which allows for mixed-use, residential, retail and office uses. VWD's 2018 Master Plan based its ultimate water demand planning on the Residential 2-4 du/ac land use. The Project is proposing 46 multi-family residential units on 8.6 acres (Residential 4-8 du/ac). Table 1 provides the average water demand generated both under the density planned for the 2018 Master Plan and for the proposed Project. The table shows that the Woodward 46 project will increase the projected average water demand from the 2018 Master Plan land use by **6,020** gallons per day.

Table 1 – Project Estimated Water Demands for Woodward 46

Land Use Type	Area (acres)	Residential Units	Duty Factor (gpd/ac)	Water Demand (gpd)
2018 Master Plan Land Use Demand				
Residential 2-4 du/ac	8.60		1,800	15,480
Total	2.51			15,480
Proposed Project Demand				
Residential 4-8 du/ac	8.60	46	2,500	21,500
Total	2.51			21,500
Water Demand Increase				6,020

Legend:



920 Zone PRV



Storage Tank

Affected Pipeline

2" Diameter Pipeline

4" Diameter Pipeline

6" Diameter Pipeline

8" Diameter Pipeline

10" Diameter Pipeline

12" Diameter Pipeline

16" Diameter Pipeline

18" Diameter Pipeline

20" Diameter Pipeline

24" Diameter Pipeline

27" Diameter Pipeline

30" Diameter Pipeline

36" Diameter Pipeline

42" Diameter Pipeline

Unaffected Pipeline

Proposed Project

Unaffected Pressure Zones

Twin Oaks 1028


Richland 920

855 Zone

Twin Oaks I
33.00 MG Tank



Twin Oaks II
40.00 MG Tank



Palomar
2.71 MG Tank

Richland II
7.05 MG Tank

Richland I
1.19 MG Tank

Figure 2

Vera Cruz
7.05 MG Tank

Vallecitos Water District
Woodward 46 Water & Sewer Study
**Existing Water Facilities in
Study Area**
February 2023
Figure 1

Legend:



920 Zone PRV



Storage Tank

Affected Pipeline

2" Diameter Pipeline

4" Diameter Pipeline

6" Diameter Pipeline

8" Diameter Pipeline

10" Diameter Pipeline

12" Diameter Pipeline

14" Diameter Pipeline

16" Diameter Pipeline

18" Diameter Pipeline

20" Diameter Pipeline

24" Diameter Pipeline

27" Diameter Pipeline

30" Diameter Pipeline


36" Diameter Pipeline

42" Diameter Pipeline

Proposed Project

Richland 920

855 Zone



Vallecitos Water District
Woodward 46 Water & Sewer Study

**Existing Water Facilities in
Study Area**

February 2023

Figure 2

Water Distribution System Analysis

The 2018 Master Plan water system distribution and pressure criteria are as follows:

Water Distribution Infrastructure Criteria

The water service pressure criteria to be met by this development are as follows:

- Minimum allowable pressure at peak hour demand: 40 psi
- Minimum allowable pressure at max day plus fire demand: 20 psi
- Maximum allowable pressure: 150 psi

The City of San Marcos Fire Marshall has set the required fire demand at **500 gpm** for the Project.

To avoid excessive velocity and headloss within the distribution system, the following pipeline design criteria was also utilized:

- Maximum allowable velocity: 7 feet per second
- Maximum allowable headloss gradient: 15 feet per 1,000 feet
- Hazen-Williams C-factor: 130

Water Model Scenarios

The following scenarios were modeled to identify system impacts that may be created by the proposed water demands, and to recommend any improvements required to provide service to the Project:

- Average Day Demand with existing demands at the Project site
- Average Day Demand with the proposed Project
- Maximum Day Demand with existing demands at the Project site
- Maximum Day Demand with the proposed Project
- Peak Hour Demand with existing demands at the Project site
- Peak Hour Demand with the proposed Project
- Maximum Day Demand plus Fire Flow with existing demands at the Project site
- Maximum Day Demand plus Fire Flow with the proposed Project

Per the 2018 Master Plan, maximum day demands for this project are 300% those of average day demands, and peak hour demands are 620% those of average day demands.

Water Model Results

Modeling focused on the infrastructure in the direct vicinity of the Project. The model found that the Project did not create any distribution system deficiencies under average day demand or maximum day plus fire flow demand conditions.

Water Storage Analysis

The 2018 Master Plan outlines VWD's potable water storage reservoirs for each pressure zone as follows:

1.5 times ADD (operational storage) + 3.0 times ADD (emergency storage) + fire flow demand = 4.5 times ADD + fire flow demand

OR

5.0 times ADD, whichever is greater.

The Project is located entirely within the VWD 855 pressure zone. Water storage for this zone is located within the 920 zone and 1028 Twin Oaks pressure zones, as shown in Figure 1. Table 2 shows the required storage in the 855, 920, and 1028 Twin Oaks pressure zones for existing and ultimate build-out (Master Plan) conditions relative to the existing storage provided within each zone.

Table 2 – Existing Reservoir Storage Capacity and Requirements

Pressure Zone	Existing ADD (MGD)	Existing Storage Requirement (MG)	Ultimate ADD (MGD)	Ultimate Storage Requirement (MG)	Existing Storage Available (MG)
855	3.74	50.05	6.79	101.25	0
920	5.61		10.40		18
1028 Twin Oaks	0.66		3.06		73
Totals	10.01	50.05	20.25	101.25	91

The Project will increase the projected average water demand by approximately **6,020** gallons per day as shown in Table 1.

The amount of additional reservoir storage required is 500% of the development's average day demand or:

$$6,020 \text{ gallons} * 500\% = 30,100 \text{ gallons}$$

The analysis finds that water storage capacity is currently available to serve the Project's increased storage requirements. Master Plan projects address and accommodate the ultimate build-out storage deficiency and Water Capital Facility Fees paid by this project will be used for the increase in storage necessitated by the Project's demand calculated above.

Water Pump Station Analysis

Since the proposed Project is located in a pressure zone that is not served by pumping, there are no impacts to existing or proposed pump stations by this Project.

WASTEWATER SYSTEM ANALYSIS


The proposed 8.6-acre Project lies completely within VWD sewer shed 17C. Figures 3 through 6 show the development's location in relation to sewer shed boundaries, identify wastewater infrastructure within the vicinity of the development, and identify the downstream collection infrastructure that will be impacted by the development.

Wastewater Flow Projections

The Project property is within the City of San Marcos' Richmar Specific Plan Area which allows for mixed-use, residential, retail and office uses. VWD's 2018 Master Plan based its ultimate water demand planning on the Residential 2-4 du/ac land use. The Project is proposing 46 multi-family residential units on 8.6 acres (Residential 4-8 du/ac). Table 3 provides the average wastewater flow generated both under the density planned for the 2018 Master Plan and with the proposed Project. The table shows that the Project will increase the projected average wastewater generation from the 2018 Master Plan land use by **4,730** gallons per day.

Table 3 – Project Estimated Wastewater Flows for Woodward 46


Land Use Type	Area (acres)	Residential Units	Duty Factor (gpd/ac)	Wastewater Flow (gpd)
2018 Master Plan Land Use Flows				
Residential 2-4 du/ac	8.60		750	6,450
Total				6,450
Proposed Project Demand				
Residential 4-8 du/ac	8.60	46	1,300	11,180
Total	1.09			11,180
Sewer Generation Increase				4,730



Legend

Affected gravity mains









8" Diameter Pipeline	Sewershed 16C
12" Diameter Pipeline	Sewershed 23C
18" Diameter Pipeline	Sewershed 24C
27" Diameter Pipeline	Sewershed 31C
36" Diameter Pipeline	
39" Diameter Pipeline	
Unaffected Pipeline	




Vallecitos Water District
Woodward 46 Water & Sewer Study
Existing Sewer Facilities in
Study Area
February 2023
Figure 4

Legend

Affected gravity mains









- | | | | |
|---|-----------------------|---|---------------|
|  | 39" Diameter Pipeline |  | Sewershed 24C |
|  | 42" Diameter Pipeline |  | Sewershed 31C |
|  | Unaffected Pipeline |  | Sewershed 23C |
|  | Sewershed 22C |  | Sewershed 32C |




Vallecitos Water District
Woodward 46 Water & Sewer Study
Existing Sewer Facilities in
Study Area
February 2023
Figure 5

Legend

Affected gravity mains

- | | | | |
|---|-----------------------|---|---------------|
|  | 39" Diameter Pipeline |  | Sewershed 24C |
|  | 42" Diameter Pipeline |  | Sewershed 31C |
|  | Unaffected Pipeline |  | Sewershed 23C |
|  | Sewershed 22C |  | Sewershed 32C |



Vallecitos Water District
Woodward 46 Water & Sewer Study
**Existing Sewer Facilities in
Study Area**
February 2023
Figure 6

Wastewater Collection System Analysis

The 2018 Master Plan outlines VWD's wastewater system design criteria which are as follows:

Wastewater Collection Infrastructure Criteria

The wastewater pipeline criteria to be met both within and downstream of the development are as follows:

- Pipes 12 inches in diameter and smaller: ½ full maximum at peak flow
- Pipes over 12 inches in diameter: ¾ full maximum at peak flow
- Minimum velocity: 2 feet per second
- Maximum velocity: 10 feet per second
- Manning's n for gravity pipes: .013
- Hazen-Williams C-factor for force mains/siphons: 120
- Slope for pipes 8 inches in diameter and smaller: 0.4% minimum
- Slope for pipes over 8 inches in diameter: to be determined by VWD

When flow depth in gravity pipes exceeds maximum levels as stated above, a pipe upsize will be specified.

Wastewater Model Scenarios

The following scenarios were modeled to identify system impacts that may be created by the proposed sewer generation, and to recommend any improvements required to provide service to the Project:

- Average Dry Weather Flow with existing flows at the Project site
- Average Dry Weather Flow with the proposed Project
- Peak Dry Weather Flow with existing flows at the Project site
- Peak Dry Weather Flow with the proposed Project
- Peak Wet Weather Flow with existing flows at the Project site
- Peak Wet Weather Flow with the proposed Project

The peak dry weather curve is:

$$\text{Peak Dry Weather Factor} = 2.16 \times (\text{Average Dry Weather Flow Rate})^{-0.1618}$$

The wet weather peak curve is:

$$\text{Peak Wet Weather Factor} = 2.78 \times (\text{Average Dry Weather Flow Rate})^{-0.087}$$

Wastewater Model Results

Modeling focused not only on the sewer collection infrastructure in the direct vicinity of the Project, but also on all downstream infrastructure from the development to Lift Station No. 1 on San Marcos Boulevard that would be impacted by the proposed Project flows (see Figures 3 - 6).

Table 4 presents a summary of the modeling results from this analysis. The modeling results showed that there are deficiencies in pipe segment W-8 under the currently approved density under peak wet weather flows during ultimate build-out conditions. The wastewater flows from the proposed Project will increase those deficiencies.

VWD's 2018 Master Plan has identified pipe segments W-8 and W-9 for upsizing from 18-inch to 24-inch diameter pipe. These segments are part of CIP project #SP-34, a phase 4 project. Phase 4 projects are planned for construction in the 2031 to 2035 timeline.

Table 4 - Wastewater Model Results and Recommended Gravity Main Improvements

				Wastewater Flows with Existing Density				Wastewater Flows with Proposed Density			
Pipe ID Number	Length (ft)	Diameter (in)	Slope	Peak Wet Weather Flow (gpm)	PWWF Depth-to-Diameter Ratio	Replacement Diameter (in)	Replacement PWWF Depth-to-Diameter Ratio	Peak Wet Weather Flow (gpm)	PWWF Depth-to-Diameter Ratio	Replacement Diameter (in)	Replacement PWWF Depth-to-Diameter Ratio
W-1	217	8	0.0660	0	0.01	8	0.01	13	0.07	8	0.07
W-2	222	12	0.0660	0	0.01	12	0.01	13	0.05	12	0.05
W-3	359	12	0.0250	1236	0.50	12	0.50	1,249	0.50	12	0.50
W-4	216	18	0.0030	1449	0.54	18	0.54	1,462	0.54	18	0.54
W-5	217	18	0.0040	1451	0.50	18	0.50	1,464	0.50	18	0.50
W-6	350	18	0.0040	1466	0.50	18	0.50	1,479	0.50	18	0.50
W-7	80	18	0.0040	1475	0.50	18	0.50	1,488	0.50	18	0.50
W-8	170	18	0.0040	2725	0.76	24	0.46	2,738	0.76	24	0.46
W-9	62	18	0.0180	2727	0.46	24	0.31	2,740	0.47	24	0.31
W-10	31	27	0.0030	2729	0.42	27	0.42	2,742	0.42	27	0.42
W-11	165	27	0.0050	2731	0.37	27	0.37	2,744	0.37	27	0.37
W-12	261	27	0.0080	2741	0.32	27	0.32	2,754	0.32	27	0.32
W-13	135	36	0.0030	6222	0.43	36	0.43	6,235	0.43	36	0.43
W-14	128	36	0.0050	6247	0.38	36	0.38	6,260	0.38	36	0.38
W-15	140	36	0.0070	6248	0.35	36	0.35	6,261	0.35	36	0.35
W-16	470	36	0.0040	6250	0.40	36	0.40	6,263	0.40	36	0.40
W-17	184	36	0.0030	6265	0.43	36	0.43	6,278	0.43	36	0.43
W-18	36	36	0.0020	6267	0.49	36	0.49	6,280	0.49	36	0.49
W-19	146	36	0.0050	6268	0.38	36	0.38	6,281	0.38	36	0.38
W-20	318	36	0.0040	6625	0.41	36	0.41	6,638	0.41	36	0.41

CIP PROJECTS: **W-8 & W-9 CIP SP-34 (Phase 4)**
 PROPOSED DENSITY: **13** GPM

Table 4 - Wastewater Model Results and Recommended Gravity Main Improvements

Pipe ID Number	Length (ft)	Diameter (in)	Slope	Wastewater Flows with Existing Density				Wastewater Flows with Proposed Density			
				Peak Wet Weather Flow (gpm)	PWWF Depth-to-Diameter Ratio	Replacement Diameter (in)	Replacement PWWF Depth-to-Diameter Ratio	Peak Wet Weather Flow (gpm)	PWWF Depth-to-Diameter Ratio	Replacement Diameter (in)	Replacement PWWF Depth-to-Diameter Ratio
W-21	39	36	0.0040	6626	0.41	36	0.41	6,639	0.41	36	0.41
W-22	319	36	0.0040	6627	0.41	36	0.41	6,640	0.41	36	0.41
W-23	38	36	0.0040	6628	0.41	36	0.41	6,641	0.41	36	0.41
W-24	139	36	0.0040	8764	0.48	36	0.48	8,776	0.48	36	0.48
W-25	294	36	0.0030	8764	0.53	36	0.53	8,777	0.53	36	0.53
W-26	12	36	0.0170	8764	0.33	36	0.33	8,777	0.33	36	0.33
W-27	438	36	0.0050	8767	0.45	36	0.45	8,780	0.45	36	0.45
W-28	229	36	0.0050	8769	0.45	36	0.45	8,782	0.45	36	0.45
W-29	371	36	0.0060	8772	0.43	36	0.43	8,785	0.43	36	0.43
W-30	124	36	0.0050	8774	0.45	36	0.45	8,787	0.45	36	0.45
W-31	167	36	0.0050	8776	0.45	36	0.45	8,789	0.45	36	0.45
W-32	201	36	0.0040	9070	0.49	36	0.49	9,083	0.49	36	0.49
W-33	91	36	0.0050	9072	0.46	36	0.46	9,085	0.46	36	0.46
W-34	220	36	0.0050	9073	0.46	36	0.46	9,086	0.46	36	0.46
W-35	286	36	0.0050	9073	0.46	36	0.46	9,086	0.46	36	0.46
W-36	210	39	0.0040	9165	0.44	39	0.44	9,178	0.44	39	0.44
W-37	176	39	0.0030	9166	0.48	39	0.48	9,179	0.48	39	0.48
W-38	271	39	0.0020	9167	0.54	39	0.54	9,180	0.54	39	0.54
W-39	297	39	0.0020	9167	0.54	39	0.54	9,180	0.54	39	0.54
W-40	452	39	0.0020	9168	0.54	39	0.54	9,181	0.54	39	0.54

CIP PROJECTS: CA-4 through CA-14 (SP-23) Phase 4

PROPOSED DENSITY: 13 GPM

Table 4 - Wastewater Model Results and Recommended Gravity Main Improvements

Pipe ID Number	Length (ft)	Diameter (in)	Slope	Wastewater Flows with Existing Density				Wastewater Flows with Proposed Density			
				Peak Wet Weather Flow (gpm)	PWWF Depth-to-Diameter Ratio	Replacement Diameter (in)	Replacement PWWF Depth-to-Diameter Ratio	Peak Wet Weather Flow (gpm)	PWWF Depth-to-Diameter Ratio	Replacement Diameter (in)	Replacement PWWF Depth-to-Diameter Ratio
W-41	337	39	0.0020	9171	0.54	39	0.54	9,184	0.54	39	0.54
W-42	123	39	0.0080	9364	0.37	39	0.37	9,377	0.37	39	0.37
W-43	58	42	0.0040	9366	0.40	42	0.40	9,379	0.40	42	0.40
W-44	308	42	0.0030	9369	0.43	42	0.43	9,382	0.43	42	0.43
W-45	69	42	0.0010	9375	0.60	42	0.60	9,388	0.60	42	0.60
W-46	448	42	0.0030	9378	0.43	42	0.43	9,391	0.43	42	0.43
W-47	448	42	0.0030	9382	0.43	42	0.43	9,395	0.43	42	0.43
W-48	404	42	0.0060	9736	0.37	42	0.37	9,749	0.37	42	0.37
W-49	404	42	0.0060	9742	0.37	42	0.37	9,755	0.37	42	0.37
W-50	368	42	0.0030	9749	0.44	42	0.44	9,762	0.44	42	0.44
W-51	368	42	0.0030	9752	0.44	42	0.44	9,765	0.44	42	0.44
W-52	368	42	0.0030	9755	0.44	42	0.44	9,768	0.44	42	0.44
W-53	120	42	0.0020	9809	0.50	42	0.50	9,822	0.50	42	0.50
W-54	352	42	0.0040	9810	0.41	42	0.41	9,823	0.41	42	0.41
W-55	472	42	0.0080	9810	0.34	42	0.34	9,823	0.34	42	0.34
W-56	467	42	0.0040	9811	0.41	42	0.41	9,824	0.41	42	0.41
W-57	460	42	0.0040	9812	0.41	42	0.41	9,825	0.41	42	0.41
W-58	8	42	0.0290	9819	0.25	42	0.25	9,831	0.25	42	0.25
W-59	310	42	0.0050	9817	0.39	42	0.39	9,830	0.39	42	0.39
W-60	372	42	0.0040	9816	0.41	42	0.41	9,829	0.41	42	0.41

CIP PROJECTS: CA-4 through CA-14 (SP-23) Phase 4

PROPOSED DENSITY: 13 GPM

Table 4 - Wastewater Model Results and Recommended Gravity Main Improvements

Pipe ID Number	Length (ft)	Diameter (in)	Slope	Wastewater Flows with Existing Density				Wastewater Flows with Proposed Density			
				Peak Wet Weather Flow (gpm)	PWWF Depth-to-Diameter Ratio	Replacement Diameter (in)	Replacement PWWF Depth-to-Diameter Ratio	Peak Wet Weather Flow (gpm)	PWWF Depth-to-Diameter Ratio	Replacement Diameter (in)	Replacement PWWF Depth-to-Diameter Ratio
W-61	355	42	0.0050	9825	0.39	42	0.39	9,838	0.39	42	0.39
W-63	190	42	0.0050	9823	0.39	42	0.39	9,836	0.39	42	0.39
W-64	316	42	0.0040	9821	0.41	42	0.41	9,834	0.41	42	0.41
W-65	94	42	0.0060	9820	0.37	42	0.37	9,833	0.37	42	0.37
W-66	112	42	0.0060	9819	0.37	42	0.37	9,832	0.37	42	0.37
W-67	100	42	0.0020	14041	0.62	42	0.62	14,054	0.62	42	0.62
W-68	347	42	0.0020	14048	0.62	42	0.62	14,061	0.62	42	0.62
W-69	18	42	0.0030	14049	0.54	42	0.54	14,062	0.55	42	0.55
W-70	10	42	0.0020	14051	0.62	42	0.62	14,064	0.62	42	0.62
W-71	10	42	0.0120	14243	0.37	42	0.37	14,255	0.37	42	0.37
W-72	73	42	0.0040	14243	0.50	42	0.50	14,255	0.50	42	0.50

CIP PROJECTS: CA-4 through CA-14 (SP-23) Phase 4

PROPOSED DENSITY: 13 GPM

Wastewater Lift Station Analysis

Lift stations are sized for peak wet weather flow with manufacturer's recommended cycling times for pumping equipment. Since the proposed Project is not located in a sewer shed that is served by a lift station, there are no lift station upgrade requirements for this project.

Parallel Land Outfall Analysis

VWD's existing land outfall is shown in Figure 7. The outfall is approximately 8 miles in length and consists of 4 gravity pipeline sections and 3 siphon sections varying in diameter from 20 inches to 54 inches. VWD maintains the entire pipeline from Lift Station No. 1 to the Encina Water Pollution Control Facility (EWPCF). From Lift Station No. 1 to El Camino Real, VWD is the sole user of this pipeline. From El Camino Real to the EWPCF, the ownership capacity is as shown in Table 5 below:

Table 5 – Land Outfall Capacity Ownership by Agency

Agency	Ownership Percentage	Capacity (MGD)
Carlsbad	23.98%	5.00
Vista	17.99%	3.75
VWD	58.03%	12.10
Totals	100.00%	20.85

The Meadowlark Water Reclamation Facility (MRF) has a capacity of 5.0 MGD with a peak wet weather capacity of 8.0 MGD. Therefore, VWD has a combined peak wet weather wastewater collection capacity of 20.10 MGD (12.10 MGD + 8.0 MGD).

VWD's 2014 average daily wastewater flow through the land outfall was 7.5 MGD. This corresponds to a peak wet weather flow of 17.5 MGD, which falls within VWD's combined peak wet weather collection capacity.


The 2018 Master Plan estimated that, under approved land uses, VWD has an ultimate build-out average dry weather flow of 14.4 MGD. This corresponds to a peak wet weather flow of 31.7 MGD, which exceeds VWD's combined peak wet weather collection capacity. To accommodate additional wastewater flows from planned development, the 2018 Master Plan recommended conveyance of peak flows to the EWPCF through a parallel land outfall.

The Project proposes to generate **4,730** gallons per day of additional average wastewater flow that was not accounted for in the Land Outfall's capacity studied in the 2018 Master Plan.

The analysis finds that outfall capacity is currently available to serve the Project's proposed wastewater generation. Wastewater Capital Facility Fees paid by this Project will be used toward design and construction of a parallel land outfall to be sized to accommodate ultimate build-out wastewater flows.

Legend

 Outfall - Gravity Mains A	 Sewershed 21C
 Outfall - Siphon A	 Sewershed 22C
 Outfall - Gravity Mains B	 Sewershed 27C
 Outfall Siphon B	 Sewershed 28C
 Outfall - Gravity Mains C	 Sewershed 29C
 Outfall - Siphon C	 Sewershed 30C
 Outfall - Gravity Mains D	 Sewershed 31C
 Unaffected Sewer Sheds	 Sewershed 32C



Wastewater Treatment Facility Analysis

VWD utilizes two wastewater treatment facilities to treat wastewater collected within its sewer service area.

- The Meadowlark Reclamation Facility (MRF) has liquids treatment capacity of up to 5.0 MGD with a peak wet weather capacity of 8.0 MGD. MRF does not have solids treatment capacity, and therefore all solids are treated at the Encina Water Pollution Control Facility (EWPCF).
- The EWPCF is located in the City of Carlsbad. This is a regional facility with treatment capacity of up to 40.51 MGD. VWD's current ownership capacity is noted below.

Solids Treatment Capacity

VWD currently owns 10.47 MGD of solids treatment capacity at EWPCF. VWD's 2014 average daily wastewater flow was 7.5 MGD. Therefore, the analysis finds that adequate solids treatment capacity exists at this time to serve the Project.

The ultimate average wastewater flow identified in the 2018 Master Plan is 14.4 MGD, resulting in a projected solids treatment capacity deficiency of 3.93 MGD. Wastewater Capital Facility Fees paid by this Project will be used towards the deficiency to accommodate the solid treatment capacity wastewater flow.

Liquids Treatment Capacity

VWD currently owns 7.67 MGD of liquids treatment capacity at the EWPCF in addition to the liquid's treatment capacity of 5.0 MGD at MRF for a total of 12.67 MGD of liquids treatment capacity. VWD's 2014 average daily wastewater flow was 7.5 MGD. Therefore, the analysis finds that adequate liquids treatment capacity exists at this time to serve the Project.

The ultimate average wastewater flow identified in the 2018 Master Plan is 14.4 MGD, resulting in a projected liquids treatment capacity deficiency of 1.73 MGD. Wastewater Capital Facility Fees paid by this Project will be used towards the deficiency to accommodate the ultimate average wastewater flow.

Ocean Disposal Capacity

VWD currently owns 10.47 MGD of ocean disposal capacity at the EWPCF. VWD's 2014 average daily wastewater flow was 7.5 MGD. Therefore, the analysis finds that adequate ocean disposal capacity exists at this time to serve the Project.

The ultimate average wastewater flow identified in the 2018 Master Plan is 14.4 MGD, resulting in an ocean disposal deficiency of 3.93 MGD. Wastewater Capital Facility Fees paid by this Project will be used towards the deficiency to accommodate the ocean disposal wastewater flow.

The District has determined that adequate wastewater treatment and disposal capacity exists for the proposed Project at this time subject to the qualifications referenced in the Conclusions and Conditions.

CONCLUSION AND CONDITIONS

The proposed Woodward 46 project is expected to increase average daily water demands by 6,020 gallons per day and wastewater flows by 4,730 gallons per day over the ultimate flows projected in the 2018 Master Plan.

The study concludes that the proposed development will result in the following impacts:

- An increase of 6,020 gallons per day in water demand for proposed project.
- An increase of 30,100 gallons of potable water storage requirement.
- An increase of 4,730 gallons per day in solids handling, liquids handling and ocean disposal capacity requirements at Encina Water Pollution Control Facility.
- An increase of 4,730 gallons per day in the parallel land outfall's capacity requirement.

The Study also concludes that there are deficiencies in the existing sewer facilities under peak wet weather flows during ultimate build-out conditions without the addition of the Project. The following improvements are needed to mitigate those deficiencies:

- Approximately 232 feet of existing 18-inch sewer main within a VWD easement along San Marcos Creek must be replaced with 24-inch main (W-8 and W-9).

VWD's 2018 Master Plan has identified pipe segments W-8 and W-9 for upsizing from 18-inch to 24-inch diameter pipe as part of CIP #SP-34, a Phase 4 project. Phase 4 projects are planned for construction in the 2031 to 2035 timeline.

Since there is currently capacity in pipes W-8 and W-9 and the need for additional capacity in these sewer mains is not anticipated until Phase 4, the CIP #SP-34 project will address and accommodate the pipeline deficiencies. Wastewater Capital Facility Fees paid by this Project will be used towards the construction of these pipelines.

The following conditions are required for providing service to the proposed Project:

- Payment of all applicable Water and Wastewater Capital Facility Fees in affect at the time service is committed in accordance with District rules and regulations.
- Construction and Board acceptance of all onsite and offsite water and sewer facilities prior to service. Includes installation of Sewer Pipes W-1 and W-2.

The District currently has water and sewer capacity available to serve the Project as proposed with the conditions herein addressed by the Developer. However, the ability to provide water and sewer service in the future depends upon ultimate build-out of the Project and could change depending upon the timing of the build-out, as well as build-outs of other development projects, continued reliable water supplies from the San Diego County Water Authority, the District's treatment capacity at the EWPCF and other factors affecting growth in the District which may change over time.

This Study is based on the current adopted land use utilized in VWD's 2018 Master Plan. The study addresses the incremental facility impacts of this Project only and does not include or consider any additional projects within VWD's service area that have deviated from adopted Master Plan land uses. Any land use changes upstream and/or downstream of the Study area may

necessitate a revision of any onsite and offsite studies. VWD shall determine when revisions to the Study are necessary. Costs for revising this Study shall be borne by the Developer. The results of this study are not the accepted conditions for the development, final conditions shall be part of the construction agreement process or issued separately by the District.